



CB TEST CERTIFICATE

Ref. Certificate No.

NL-17081/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Moulded case circuit-breaker		
Applicant:	Hager Electro Sas	132 Boulevard d' Europe 67215 Obernai Cedex	France
Manufacturer:	Terasaki Electric Co. Ltd.	7-2-10 Hannan-cho Abeno-ku, 545-0021 Osaka	Japan
Factory:	Terasaki Electric (M) SDN, BHD	Lot 3, Jalan 16/13D, 40000 Shah Alam, Selangor Darul Ehsan	Malaysia
Rating and principal characteristics:	3P, 3P+N, 4P; Ue = 415 Vac; In = from 100 to 250 A; Icu = 40 kA; Ics = 20 kA; Uimp = 8 kV; Ui = 800 V; 50 Hz; Utilization Category A.		
Trade mark (if any):	HAGER		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	h3 x250 / HNB...*, h3 x250 / HNB...P, h3 x250 / HNB...U (* = country version designation A;B;C...;Y;Z)		
Additional information:	A1: editorial change		
Sample of product tested to be in conformity with IEC:	60947-1(ed.5) 60947-2(ed.4)		
Test Report Ref. No:	2119511.50 to 2119511.55		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2009-11-26