

CERTIFICATE

Issued to:
Applicant:
AB Plast S.r.l. Hager Group
Via dell' Artigianato 6
25080 Molinetto Di Mazzano (BS), Italy

Manufacturer/Licensee:
AB Plast S.r.l. Hager Group
Via dell' Artigianato 6
25080 Molinetto Di Mazzano (BS), Italy

Product(s) : combinations of switches and socket-outlets
Trade name(s) : BERKER
Type(s)/model(s) : WP/WP/47xxxxx

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:1999 + A1: 2002 + A2: 2008, IEC 60884-1:2002 + A1: 2006, NEN 1020:1987 + A2: 2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2161960

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 4 September 2013 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2165049.05

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	combinations of switches and socket-outlets
trade name	:	BERKER
types	:	WP/WP/47xxxxxx
pattern no.	:	6
method of mounting	:	surface type
cover	:	housing of thermoplastic material
terminals	:	screwless terminals
rated current	:	socket-outlet part 16 A switch part 10 AX
rated voltage	:	250 V~
degree of protection	:	IP44
design	:	combination of a rocker switch and socket-outlet with side earthing-contacts, see for the product code the overview in the annex
markings	:	tradename, series-indication and electrical rating on the switch and socket-outlet part

TESTS**Test requirements**

EN 60669-1:1999 + A1:2002 + A2:2008
IEC 60884-1:2002 + A1:2006
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2165049.05.


Remarks

This certificate is based on the SGS CEBEC CB Test Certificate BE-4342/x and Notification of Test Results CCA/B6/2013.

Conclusion

The examination proved that all test requirements were met.

Tested by : SGS CEBEC
Checked by : H.R.M. Barends

**Factory locations**

Berker Polska Sp.z.o.o.
Ul. Sredzka 19, 62-035, Kornik
Poland

Technical code	Product description	Brand	Switch Pattern Nbr.	Product code
w2y1803_00	COMPLETE PRODUCT - SCHUKO SOCKET WITH 2 WAY SWITCH IN VERTICAL BOX GREY WITHOUT SHUTTERS	Berker	6	47803505
w2y1804_00	COMPLETE PRODUCT - SCHUKO SOCKET WITH 2 WAY SWITCH IN VERTICAL BOX WHITE WITHOUT SHUTTERS	Berker	6	47803502
w2y1805_00	COMPLETE PRODUCT - SCHUKO SOCKET WITH DOUBLE 2WAY SWITCH COMMON ENTRANCE IN VERTICAL BOX GREY WITHOUT SHUTTERS	Berker	6	47903505
w2y1806_00	COMPLETE PRODUCT - SCHUKO SOCKET WITH DOUBLE 2WAY SWITCH COMMON ENTRANCE IN VERTICAL BOX WHITE WITHOUT SHUTTERS	Berker	6	47903502