

CERTIFICATE

Issued to:
Applicant:
AB Plast S.r.l. Hager Group
Via dell' Artigianato 6
25080 Molinetto Di Mazzano (BS), Italy

Manufacturer/Licensee:
AB Plast S.r.l. Hager Group
Via dell' Artigianato 6
25080 Molinetto Di Mazzano (BS), Italy

Product(s) : combinations of rocker switches
Trade name(s) : BERKER, HAGER
Type(s)/model(s) : WP/304835xx, WP/WNAxxx(x)

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:1999 + A1: 2002 + A2: 2008
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2161960

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 4 September 2013 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2165049.03

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	combinations of rocker switches
trade names	:	BERKER, HAGER
types	:	WP/304835xx, WP/WNAxxx(x)
pattern no.	:	6+6
method of mounting	:	surface type
cover	:	housing of thermoplastic material
terminals	:	screwless terminals
rated current	:	10 AX
rated voltage	:	250 V~
degree of protection	:	IP55
	:	the switch could also be mounted in a double and three-fold housing, see for product code the overview in the annex
markings	:	tradename, series-indication and electrical ratings on the switch

TESTS**Test requirements**

EN 60669-1:1999 + A1:2002 + A2:2008

Test result

The test results are laid down in DEKRA test file 2165049.03.

Remarks

This certificate is based on the SGS CEBEC Notification of Test Results CCA/B6/2013.

Conclusion

The examination proved that all test requirements were met.

Tested by : SGS CEBEC
Checked by : H.R.M. Barends

**Factory locations**

Berker Polska Sp.z.o.o.
Ul. Sredzka 19, 62-035, Kornik
Poland

Technical code	Brand	Product Code	Product description	SW Scheme	Pattern number	IP code
w2y1707_00	Hager	WNA040	ROCKER WITH MECH - DOUBLE 2 WAY SWITCH SEPARATE ENTRANCE GREY	Double 2 way switch	6	IP55
w2y1708_00	Hager	WNA040B	ROCKER WITH MECH - DOUBLE 2 WAY SWITCH SEPARATE ENTRANCE WHITE	Double 2 way switch	6	IP55
w2y1708_00	Berker	30483512	ROCKER WITH MECH - DOUBLE 2 WAY SWITCH SEPARATE ENTRANCE WHITE	Double 2 way switch	6	IP55
w2y1707_00	Berker	30483515	ROCKER WITH MECH - DOUBLE 2 WAY SWITCH SEPARATE ENTRANCE GREY	Double 2 way switch	6	IP55